

## BRE Global Ireland

### Notified Body No. 2831

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance 2831-CPR-F1775

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

### Esento Evoque 16, 24 and 32 Zone Conventional Control and Indicating Equipment *(For full product details and conditions of use refer to appendix)*

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

**Haes Technologies Limited**  
**Unit 3, Horton Industrial Park**  
**Horton Road**  
**West Drayton, Middlesex**  
**UB7 8JD**  
**United Kingdom**

**Haes Technologies Limited**  
**Unit 3, Horton Industrial Park**  
**Horton Road**  
**West Drayton, Middlesex**  
**UB7 8JD**  
**United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

### EN 54-2:1997 + A1:2006 - Control and indicating equipment EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### **the constancy of performance of the construction product.**

This certificate was first issued on 23 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



E. Mattie-Suleiman, Certification Engineer

Date of First Issue: 23 October 2019

Date of Issue: 29 July 2020

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie).

## BRE Global Ireland

### Notified Body No. 2831

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland

T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## APPENDIX to Certificate of constancy of performance: 2831-CPR-F1775

### Esento Evoque 16, 24 and 32 Zone Conventional Control and Indicating Equipment

#### Esento Evoque 16 Zone Conventional Control Panel

Incorporating as modular units:  
TPCA10 32 Zone LED display PCB  
TPCA11-16 16 Zone Main PCB  
TPCA12 Power supply PCB

and as optional modules

TPCR01 Relay PCB  
TPCR03 Isolate Switch PCB  
TPCA09 Sounder Card PCB  
TPCA08 Output Card PCB  
TPCA05 XLEN Communications Board

#### Esento Evoque 24 Zone Conventional Control Panel

Incorporating as modular units:  
TPCA10 32 Zone LED display PCB  
TPCA11-24 24 Zone Main PCB  
TPCA12 Power supply PCB

and as optional modules

TPCR01 Relay PCB  
TPCR03 Isolate Switch PCB  
TPCA09 Sounder Card PCB  
TPCA08 Output Card PCB  
TPCA05 XLEN Communications Board

#### Esento Evoque 32 Zone Conventional Control Panel

Incorporating as modular units:  
TPCA10 32 Zone LED display PCB  
TPCA11-32 32 Zone Main PCB  
TPCA12 Power supply PCB

and as optional modules

TPCR01 Relay PCB



E. Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 29 July 2020

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie).

## BRE Global Ireland

### Notified Body No. 2831

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland

T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

### APPENDIX to Certificate of constancy of performance: 2831-CPR-F1775

TPCR03 Isolate Switch PCB  
TPCA09 Sounder Card PCB  
TPCA08 Output Card PCB  
TPCA05 XLEN Communications Board

Certified with the following options with requirements from EN 54 Part 2:

- 7.8 Output to fire alarm devices
- 7.9.1 Output to fire alarm routing equipment
- 7.11 Delays to outputs
- 7.12.1 Dependency on more than one alarm signal type A
- 7.12.2 Dependency on more than one alarm signal type B
- 7.12.3 Dependency on more than one alarm signal type C
- 10 Test condition

#### Note:

1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.



E. Mattie-Suleiman, Certification Engineer,  
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 29 July 2020

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie).