

## **DECLARATION OF PERFORMANCE**

In accordance with Construction Products Regulation EU No. 305/2011

**No: HAES-01501-MZAOV-DoP, Issue 1**

1. Unique Product identification code of the product type:  
**Multizone Automatically Opening Vent fire detection and fire alarm control panels**
2. Type, batch or serial number or any other element allowing identification of the construction product as required under article 11 (4) of the CPR:  
**MZAOV-1001 (3A PSU)**  
**MZAOV-1002 (5A PSU)**  
**MZAOV-1003 (10A PSU)**
3. Intended use of the construction product:  
**Electrical automatic control of multizone smoke and heat exhaust vents**
4. Name, registered trade name or registered trademark and contact address of the manufacturer:  
**Haes Technologies Limited**  
**Unit 3, Horton Industrial Park,**  
**West Drayton, Uxbridge, Middlesex UB7 8JD**  
**United Kingdom**
5. Where applicable; name and contact address of the authorised representative whose mandate covers the tasks specified in article 12 (2):  
**Not applicable**
6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:  
**System 1**
7. In the case of the Declaration of performance concerning a construction product covered by a harmonized standard: **EN 12101-10:2005**  
**CNBOP-PIB**  
Have performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificate of constancy of performance:  
**1438-CPR-0739**
8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:  
**Not applicable, see item 7**

9. Declared performance:

Harmonized Technical Specification		BS EN 12101-10:2005
Essential characteristics	Performance	Clause
<b>Operational reliability</b>		
Functions	Pass	6
Materials design and manufacture	Pass	7
<b>Operating parameters in fire conditions</b>		
General provisions	Pass	4.1
Power supply source – general provisions	Not applicable	5.2.1
<b>Response time</b>		
General provisions	Pass	4.1
Power supply source – general provisions	Not applicable	5.2.1
Power supply from reserve source (battery)	Pass	6.2.2
Power supply from reserve source (generator)	Not applicable	6.3.1

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

(Name and function)

Andrew Cook Compliance Manager

(Place and date of issue)

West Drayton, UK 16/12/2020



..... (Signature)