

## EC Declaration of Conformity

In accordance with EN ISO/IEC 17050-1:2010

We: **Haes Technologies Limited**  
Of: Unit 3, Horton Industrial Park,  
West Drayton, Uxbridge, Middlesex UB7 8JD

In accordance with the following Directives:

2014/35/EU	Low Voltage Directive (LVD)
2014/30/EU	Electromagnetic Compatibility (EMC) Directive
2015/863/EU	Restriction of Hazardous Substances (EU) (RoHS 3.0)

Hereby declare that:

Part No. Reference	Equipment
ESA-1001	Esprit Argus addressable fire alarm control panel, 1 to 2 loop, 1.2A PSU
ESA-1002	Esprit Argus addressable fire alarm control panel, 1 to 4 loop, 3.4A PSU
ESA-1006	Esprit Apollo addressable fire alarm control panel, 1 to 2 loop, 3.4A PSU
ESA-1007	Esprit Apollo addressable fire alarm control panel, 1 to 4 loop, 3.4A PSU
ESA-2001	Esprit Addressable Repeater

Is in conformity with the applicable requirements of the following documents:

Ref No.	Edition/Date	Title
BS EN 50130-4:	2011 + A1:2014	Alarm Systems. Electromagnetic compatibility. Product family standard: Immunity requirements for components of fire, Intruder, hold up, CCTV, access control and social alarm systems
BS EN 61000-6-3:	2007 + A1:2011	Electromagnetic compatibility (EMC). Generic standards. Emission Standard for residential, commercial and light industrial environments
BS EN 62368-1	2014 + A11:2017	Information and communication technology equipment, Safety requirements

I hereby declare that the equipment named above has been designed to comply with all the relevant sections of the above referenced specifications; the units comply with all Essential Requirements of the Directives.

Signed:



Name: Robert Allan  
Position: Research and Development Manager  
On: 10/08/2022

Document Ref. No:  
Haes-DOC01495-ESA-CE  
Issue 2

Manufacturers and suppliers of fire detection and alarm equipment