



Haes Technologies Ltd, Unit 3, Horton Industrial Park, West Drayton, UB7 8JD, UK
Tel: +44 (0) 1895 546205 • e: info@haes-tech.com • web: www.haes-tech.com

EU Declaration of Conformity

In accordance with EN ISO/IEC 17050-1:2010

We: **Haes Technologies Limited**
Of: Unit 3, Horton Industrial Park,
West Drayton, Uxbridge, Middlesex UB7 8JD

In accordance with the following Directives:

2014/35/EU	Low Voltage Directive (LVD)
2014/30/EU	Electromagnetic Compatibility (EMC) Directive
2011/65/EU	Restriction of Hazardous Substances in Electrical and Electronic Equipment (RoHS 3.0)

Hereby declare that:

Part No. Reference	Equipment
SZAOV-1001	Single zone Automatically Opening Vent fire detection and fire alarm control panel, 3A PSU

Is in conformity with the applicable requirements of the following documents:

Ref No.	Edition/Date	Title
BS EN 50130-4:	2011 + A1:2014	Alarm Systems. Electromagnetic compatibility. Product family standard: Immunity requirements for components of fire, Intruder, hold up, CCTV, access control and social alarm systems
BS EN 61000-6-3:	2007 + A1:2011	Electromagnetic compatibility (EMC). Generic standards. Emission Standard for residential, commercial and light industrial environments
BS EN 60950-1	2006 + A2:2013	Information technology equipment, Safety general requirements

I hereby declare that the equipment named above has been designed to comply with all the relevant sections of the above referenced specifications; the units comply with all Essential Requirements of the Directives.

Signed:



Name: Robert Alan
Position: R&D Manager
On: 12/09/2022

Document Ref. No:
Haes-01578-SZAOV-CE
Issue 1

Manufacturers and suppliers of fire detection and alarm equipment

Directors: J. Ivey, S. Butterfield, L. Ivey
Reg Office: As above. VAT No. 334 3768 90 Reg No. 1427223 UK
Registered in England